

Expertise Statement

455 31092/7e dated 18. November 2008

referring to Evidence of Performance
403 37092/3 dated 4 July 2006
thermal transmittance U_m of roof windows



Translation of expertise statement 403 31092/7 dated 10 July 2006

Client **VELUX A/S**
Ådalsvej 99

2970 Hørsholm
Denmark

Basis

EN ISO 12567-2 : 2005
Thermal performance of windows and doors - Determination of thermal transmittance by hot box method - Part 2: Roof windows and other projecting windows
Test report 403 37092/3 dated 4 July 2006

Product	Roof window
Designation	VELUX GGU 73
Overall dimensions (W x H)	see „Validity“
(Frame) Material	Polyurethane-foam (high density) with core made of wood, Cover plate in aluminum / coated
Type of opening	horizontal pivot window Insulating glass unit VELUX 73 Configuration: <u>SSG4/14,5/LSG6</u> mm Gas filling: 95 % Argon Coating: IR-coating (V6) on Pos. 2 ($\epsilon_n=0.03$)
Infill panel	Edge seals: Stainless steel Installation depth in test wall: 49 mm
Installation	with roof flashing in aluminium / coated 2 ventilation opening in casement member above, coverage of the slit exterior: cover plate in aluminum / coated with filters and inlay made of thermal insulation (polystyrene), coverage of the slit interior: cover in Polyurethane-foam (high density)
Special features	

Instructions for use

The present expert statement in conjunction with the above basis serves to demonstrate the „thermal transmittance U_m of roof windows.“

Validity

The testing and/or the evidence of performance „thermal transmittance U_m of windows“ does not allow any statement to be made on any further characteristics relevant to performance and quality of the present construction.

The thermal transmittance U_m has been determined for the reference size 1140 mm x 1400 mm in accordance with the specifications of the standard EN 14351-1

Thermal transmittance



$$U_m = 1.4 \text{ W}/(\text{m}^2 \cdot \text{K})^*$$

*) According to EN ISO 12567-2 : 2005 based on test report 403 31092/3 dated 4 July 2006 and the in existing statements described deviations to the examined product variants.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.


The cover sheet can be used as abstract.

Contents


The report comprises a total of 7 pages

- Cover Sheet
- Expertise Statement
- 1 Order
- 2 Basis
- 3 Assessment
- 4 Results and statements
- 5 Annexes

ift Rosenheim
18. November 2008


Michael Rossa, Dipl.-Phys.
Head of Testing Department
ift Centre Glass, Building Materials & Building Physics




Konrad Huber, Dipl.-Ing. (FH)
Test engineer
ift Centre Glass, Building Materials & Building Physics



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Straße 7-9
D-83026 Rosenheim
Tel. +49 (0) 8031 / 261-0
Fax +49 (0) 8031 / 261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 38 22
BLZ 711 500 00

Anerkannte Prüf-, Überwachungs- und Zertifizierungsstelle nach Landesbauordnung: BAY18
Notifizierung in Europa: Nr. 0757